

## DECLARATION OF CONFORMITY

We hereby declare that the equipment described is designed, produced and tested in accordance with recognized standards and procedures, and is in conformity with the provisions of the following EEC directives:

Electromagnetic Compatibility Directive 2004/108/EC  
Standard: En 61000

Machinery Directive 2006/42/EC Standard: NS-EN ISO 12100:2010

Pressure Equipment Directive (PED) 97/23/EC. Harmonized with EN 13445  
Main heat exchanger category: [2] Art. 3, §3  
Surge tank: Category SEP

ATEX Directive, 94/9/EC  
Harmonized entirely or in part with: EN 13463-1: 2009, EN 60079-0: 2012, EN 60079-1: 2007,  
EN 60079-7: 2007, EN 60079-11: 2007, EN 60079-15: 2010, EN 60079-18: 2009, EN  
60079-25: 2010

All activities are covered by Frank Mohn Flatøy AS Quality System, which is certified by Det Norske Veritas, Høvik, Norway, to comply with EN - ISO 9001-2008.

This Declaration is issued in accordance to procedure 30.3.02 in Frank Mohn Flatøy's Operasjonsmanual.

Product: FIRE WATER PUMP PACKAGES  
EX MARKING: EX II 3 G IIB T3

Tag no.: 71-PA-0001A/B/C, 71-PS  
-1101/1201/1301

Customer: TECHNIP FRANCE

Project: 623708 5/98 HEJRE DEVELOPMENT PROJECT / PLATFORM EPC

Producer: FRAMO FLATØY AS  
FLATØYVEGEN 24  
N - 5918 FREKHAUG

NORWAY

Phone: (47) 55 99 94 00 Fax: (47) 55 99 95 81

Place: **Flatøy**

Date: 07.10.2016

Name of authorized person: **Miriam Drengenes**

Sign: Miriam Drengenes  
Position: **Quality Assurance Manager**

